

## Сводная ведомость

Результатов контрольных замеров нагрузок в сетях ООО "АТЭК74"

за 19 июня 2024 года

№ ТП	Сек (Щит)	Группа (ВЛ)	UАО, В	UBO, В	UCO, В	IA, А	IB, А	IC, А	P, Вт
ТП-1482	1	0	226,0	229,0	227,0	0,0	0,0	0,0	0,0
ТП-1482	1	6	226,0	229,0	227,0	0,0	0,0	0,0	0,0
ТП-1482	2	0	224,0	224,0	229,0	1,4	0,81	0,67	648,5
ТП-1482	2	12	224,0	224,0	229,0	87,0	43,0	38,0	37822,0
ТП-3087	1	0	228,0	229,0	227,0	0,28	0,22	0,26	173,2
ТП-3087	1	5	228,0	229,0	227,0	15,0	13,0	14,0	9575,0
ТП-3087	2	0	235,0	238,0	235,0	0,72	0,45	0,45	382,1
ТП-3087	2	5	235,0	238,0	235,0	31,0	25,0	14,0	16525,0
ТП-34	1	0	233	232	233	206	213	224	149606,0
ТП-34	1	1	233	232	233	16	15	16	10936,0
ТП-34	1	2	233	232	233	23	14	23	13966,0
ТП-34	1	3	233	232	233	18	17	16	11866,0
ТП-34	1	4	233	232	233	16	15	16	10936,0
ТП-34	1	5	233	232	233	15	16	17	11168,0
ТП-34	1	6	233	232	233	13	14	13	9306,0
ТП-34	1	7	233	232	233	17	10	19	10708,0
ТП-34	1	8	233	232	233	19	22	20	14191,0
ТП-34	1	9	233	232	233	10	15	12	8606,0
ТП-34	1	10	233	232	233	14	15	16	10470,0
ТП-34	1	11	233	232	233	18	17	16	11866,0
ТП-34	1	12	233	232	233	17	10	13	9310,0
ТП-34	1	13	233	232	233	14	15	16	10470,0
ТП-34	1	14	233	232	233	18	12	19	11405,0
ТП-34	1	15	233	232	233	15	17	14	10701,0
ТП-34	2	0	232	231	232	210	220	215	149420,0
ТП-34	2	1	232	231	232	15	16	17	11120,0
ТП-34	2	2	232	231	232	17	18	19	12510,0
ТП-34	2	3	232	231	232	14	15	16	10425,0
ТП-34	2	4	232	231	232	18	17	16	11815,0
ТП-34	2	5	232	231	232	14	15	16	10425,0
ТП-34	2	6	232	231	232	10	15	12	8569,0
ТП-34	2	7	232	231	232	13	14	13	9266,0
ТП-34	2	8	232	231	232	16	15	16	10889,0
ТП-34	2	9	232	231	232	15	16	17	11120,0
ТП-34	2	10	232	231	232	20	25	22	15519,0
ТП-34	2	11	232	231	232	16	15	16	10889,0
ТП-34	2	12	232	231	232	26	25	26	17839,0
ТП-34	2	13	232	231	232	18	17	19	12511,0
ТП-34	2	15	232	231	232	15	17	14	10655,0
ТП-36	1	0	230	232	231	180	200	195	132845,0
ТП-36	1	1	230	232	231	25	26	27	18019,0
ТП-36	1	2	230	232	231	17	18	19	12475,0
ТП-36	1	3	230	232	231	14	15	16	10396,0
ТП-36	1	4	230	232	231	18	17	16	11780,0
ТП-36	1	5	230	232	231	14	15	16	10396,0
ТП-36	1	6	230	232	231	20	25	22	15482,0
ТП-36	1	7	230	232	231	13	14	13	9241,0
ТП-36	1	8	230	232	231	16	15	16	10856,0
ТП-36	1	9	230	232	231	20	16	23	13625,0

№ ТП	Сек (Щит)	Группа (ВЛ)	УАО, В	УВО, В	УСО, В	IA, А	IB, А	IC, А	P, Вт
ТП-36	1	10	230	232	231	27	25	28	18478,0
ТП-36	1	11	230	232	231	16	15	16	10856,0
ТП-36	1	12	230	232	231	18	17	16	11780,0
ТП-36	1	13	230	232	231	13	14	13	9241,0
ТП-36	1	14	230	232	231	14	15	16	10396,0
ТП-36	1	18	230	232	231	8	10	7	5777,0
ТП-36	2	0	232	233	232	216	211	226	151707,0
ТП-36	2	1	232	233	232	14	15	16	10455,0
ТП-36	2	2	232	233	232	15	16	17	11152,0
ТП-36	2	3	232	233	232	18	17	16	11849,0
ТП-36	2	4	232	233	232	15	17	14	10689,0
ТП-36	2	5	232	233	232	16	17	18	11849,0
ТП-36	2	6	232	233	232	24	25	25	17193,0
ТП-36	2	7	232	233	232	19	20	18	13244,0
ТП-36	2	8	232	233	232	29	32	30	21144,0
ТП-36	2	9	232	233	232	20	22	21	14638,0
ТП-36	2	10	232	233	232	20	19	24	14635,0
ТП-36	2	11	232	233	232	15	17	14	10689,0
ТП-36	2	12	232	233	232	16	17	18	11849,0
ТП-36	2	13	232	233	232	14	15	15	10223,0
ТП-36	2	14	232	233	232	19	20	18	13244,0
ТП-20	1	0	222,0	222,0	222,0	0,70	0,61	0,60	424,0
ТП-20	1	1	222,0	222,0	222,0	41,0	39,0	43,0	27306,0
ТП-20	1	2	222,0	222,0	222,0	28,0	14,0	34,0	16872,0
ТП-20	1	3	222,0	222,0	222,0	29,0	33,0	42,0	23088,0
ТП-20	1	4	222,0	222,0	222,0	39,0	42,0	48,0	28638,0
ТП-20	1	5	222,0	222,0	222,0	32,0	30,0	51,0	25086,0
ТП-20	1	6	222,0	222,0	222,0	0,6	6,0	2,0	1909,2
ТП-20	1	15	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-20	2	0	222,0	222,0	221,0	0,00	0,01	0,01	4,4
ТП-20	2	1	222,0	222,0	221,0	0,0	0,0	0,0	0,0
ТП-20	2	2	222,0	222,0	221,0	0,0	0,0	0,0	0,0
ТП-20	2	3	222,0	222,0	221,0	0,0	0,0	0,0	0,0
ТП-20	2	4	222,0	222,0	221,0	0,0	0,0	0,0	0,0
ТП-20	2	5	222,0	222,0	221,0	0,0	0,0	0,0	0,0
ТП-20	2	6	222,0	222,0	221,0	1,8	1,2	2,4	1196,4
ТП-27	1	0	232	231	232	25,0	24,0	26,0	17376,0
ТП-27	1	1	232	231	232	10,0	12,0	11,0	7644,0
ТП-27	1	2	232	231	232	1,0	1,0	1,0	695,0
ТП-27	1	3	232	231	232	12,0	10,0	13,0	8110,0
ТП-27	1	4	232	231	232	1,0	1,0	1,0	695,0
ТП-27	2	0	233	233	234	175,0	165,0	180,0	121340,0
ТП-27	2	1	233	233	234	11,0	10,0	12,0	7701,0
ТП-27	2	2	233	233	234	10,0	12,0	13,0	8168,0
ТП-27	2	3	233	233	234	22,0	25,0	21,0	15865,0
ТП-27	2	4	233	233	234	129,0	134,0	140,0	94039,0
ТП-30	1	17	232	231	232	31,0	35,0	32,0	22701,0
ТП-30	2	0	234	232	233	95,0	99,0	102,0	68964,0
ТП-30	2	16	234	232	233	0,0	0,0	0,0	0,0
ТП-30	2	17	234	232	233	1,0	1,0	1,0	699,0
ТП-31	1	0	232	231	232	336,0	372,0	344,0	243692,0

№ ТП	Сек (Щит)	Группа (ВЛ)	УАО, В	УВО, В	УСО, В	IA, А	IB, А	IC, А	P, Вт
ТП-31	1	1	232	231	232	46,0	49,0	45,0	32431,0
ТП-31	1	2	232	231	232	28,0	31,0	27,0	19921,0
ТП-31	1	3	232	231	232	23,0	25,0	24,0	16679,0
ТП-31	1	4	232	231	232	19,0	22,0	24,0	15058,0
ТП-31	1	5	232	231	232	27,0	29,0	25,0	18763,0
ТП-31	1	6	232	231	232	12,0	10,0	11,0	7646,0
ТП-31	1	7	232	231	232	4,0	5,0	4,0	3011,0
ТП-31	1	8	232	231	232	29,0	32,0	30,0	21080,0
ТП-31	1	9	232	231	232	20,0	22,0	18,0	13898,0
ТП-31	1	10	232	231	232	5,0	4,0	3,0	2780,0
ТП-31	1	11	232	231	232	28,0	30,0	26,0	19458,0
ТП-31	1	12	232	231	232	8,0	10,0	9,0	6254,0
ТП-31	1	13	232	231	232	25,0	28,0	27,0	18532,0
ТП-31	1	14	232	231	232	15,0	19,0	20,0	12509,0
ТП-31	1	15	232	231	232	2,0	1,0	2,0	1159,0
ТП-31	1	16	232	231	232	24,0	24,0	27,0	17376,0
ТП-31	1	17	232	231	232	1,0	1,0	1,0	695,0
ТП-31	2	0	234	232	233	216,0	281,0	268,0	178180,0
ТП-31	2	1	234	232	233	18,0	25,0	22,0	15138,0
ТП-31	2	2	234	232	233	10,0	9,0	11,0	6991,0
ТП-31	2	3	234	232	233	6,0	7,0	8,0	4892,0
ТП-31	2	4	234	232	233	17,0	20,0	18,0	12812,0
ТП-31	2	5	234	232	233	12,0	15,0	13,0	9317,0
ТП-31	2	6	234	232	233	4,0	3,0	4,0	2564,0
ТП-31	2	7	234	232	233	7,0	8,0	6,0	4892,0
ТП-31	2	8	234	232	233	15,0	20,0	21,0	13043,0
ТП-31	2	9	234	232	233	25,0	27,0	23,0	17473,0
ТП-31	2	10	234	232	233	8,0	10,0	7,0	5823,0
ТП-31	2	11	234	232	233	10,0	12,0	14,0	8386,0
ТП-31	2	12	234	232	233	10,0	15,0	9,0	7917,0
ТП-31	2	13	234	232	233	31,0	35,0	28,0	21898,0
ТП-31	2	14	234	232	233	10,0	14,0	11,0	8151,0
ТП-31	2	16	234	232	233	1,0	1,0	1,0	699,0
ТП-31	2	17	234	232	233	2,0	2,0	1,0	1165,0
ТП-31	2	18	234	232	233	1,0	1,0	1,0	699,0
ТП-1	1	0	234,0	233,0	233,0	0,66	0,37	0,69	401,4
ТП-1	1	1	234,0	233,0	233,0	14,1	13,9	14,5	9916,6
ТП-1	1	2	234,0	233,0	233,0	8,9	9,0	9,0	6276,6
ТП-1	1	3	234,0	233,0	233,0	15,8	16,3	16,6	11362,9
ТП-1	1	4	234,0	233,0	233,0	19,0	18,7	19,3	13300,0
ТП-1	1	11	234,0	233,0	233,0	37,4	36,9	37,6	26110,1
ТП-1	1	12	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-1	2	0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-1	2	1	234,0	234,0	233,0	14,0	13,9	14,5	9907,1
ТП-1	2	2	234,0	234,0	233,0	13,7	13,9	14,1	9743,7
ТП-1	2	3	234,0	234,0	233,0	13,8	14,0	13,5	9650,7
ТП-1	2	4	234,0	234,0	233,0	19,0	19,5	19,7	13599,1
ТП-1	2	11	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-1	2	12	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-2	1	0	236,0	235,0	235,0	0,19	0,20	0,28	157,6
ТП-2	1	1	236,0	235,0	235,0	21,0	20,0	33,0	17411,0

№ ТП	Сек (Щит)	Группа (ВЛ)	УАО, В	УВО, В	УСО, В	IA, А	IB, А	IC, А	P, Вт
ТП-2	1	2	236,0	235,0	235,0	15,0	11,0	22,0	11295,0
ТП-2	1	7	236,0	235,0	235,0	3,0	2,0	3,0	1883,0
ТП-2	1	9	236,0	235,0	235,0	10,0	15,0	14,0	9175,0
ТП-2	1	10	236,0	235,0	235,0	0,3	0,3	1,5	493,8
ТП-2	1	11	236,0	235,0	235,0	3,0	0,2	1,0	990,0
ТП-2	1	12	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-2	2	0	238,0	238,0	237,0	0,29	0,36	0,41	251,9
ТП-2	2	1	238,0	238,0	237,0	0,0	0,0	0,0	0,0
ТП-2	2	2	238,0	238,0	237,0	35,0	7,0	11,0	12603,0
ТП-2	2	7	238,0	238,0	237,0	25,0	27,0	18,0	16642,0
ТП-2	2	9	238,0	238,0	237,0	30,0	11,0	37,0	18527,0
ТП-2	2	11	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-2	2	12	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-3	1	0	236,0	235,0	235,0	0,26	0,23	0,27	178,9
ТП-3	1	1	236,0	235,0	235,0	10,0	17,0	13,0	9410,0
ТП-3	1	2	236,0	235,0	235,0	9,0	11,0	15,0	8234,0
ТП-3	1	3	236,0	235,0	235,0	11,0	16,0	9,0	8471,0
ТП-3	1	4	236,0	235,0	235,0	14,0	7,0	6,0	6359,0
ТП-3	1	5	236,0	235,0	235,0	15,0	11,0	6,0	7535,0
ТП-3	1	8	236,0	235,0	235,0	0,06	0,09	0,06	49,4
ТП-3	1	12	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-3	2	0	238,0	237,0	236,0	0,33	0,22	0,27	194,4
ТП-3	2	1	238,0	237,0	236,0	14,0	20,0	12,0	10904,0
ТП-3	2	2	238,0	237,0	236,0	20,0	22,0	18,0	14222,0
ТП-3	2	3	238,0	237,0	236,0	9,0	10,0	7,0	6164,0
ТП-3	2	4	238,0	237,0	236,0	25,0	5,0	9,0	9259,0
ТП-3	2	5	238,0	237,0	236,0	20,0	9,0	15,0	10433,0
ТП-3	2	11	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-3	2	12	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-4	1	0	236,0	236,0	235,0	0,28	0,13	0,17	136,7
ТП-4	1	1	236,0	236,0	235,0	7,0	9,0	12,0	6596,0
ТП-4	1	2	236,0	236,0	235,0	5,0	10,0	4,0	4480,0
ТП-4	1	3	236,0	236,0	235,0	83,0	10,0	16,0	25708,0
ТП-4	1	6	236,0	236,0	235,0	4,0	1,0	1,0	1415,0
ТП-4	1	9	236,0	236,0	235,0	0,0	0,0	0,0	0,0
ТП-4	2	0	234,0	234,0	233,0	0,18	0,13	0,24	128,5
ТП-4	2	1	234,0	234,0	233,0	20,0	8,0	34,0	14474,0
ТП-4	2	2	234,0	234,0	233,0	10,0	4,0	4,0	4208,0
ТП-4	2	3	234,0	234,0	233,0	11,0	26,0	8,0	10522,0
ТП-4	2	9	234,0	234,0	233,0	0,0	0,0	0,0	0,0
ТП-5	1	0	236,0	235,0	235,0	0,40	0,16	0,18	174,3
ТП-5	1	1	236,0	235,0	235,0	20,0	19,0	28,0	15765,0
ТП-5	1	2	236,0	235,0	235,0	10,0	12,0	7,0	6825,0
ТП-5	1	3	236,0	235,0	235,0	28,0	17,0	14,0	13893,0
ТП-5	1	11	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-5	1	12	236,0	235,0	235,0	0,0	19,0	20,0	9165,0
ТП-5	1	15	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-5	2	0	223,0	222,0	222,0	0,06	0,25	0,10	91,1
ТП-5	2	1	223,0	222,0	222,0	0,27	0,24	0,29	177,9
ТП-5	2	2	223,0	222,0	222,0	0,6	29,0	12,0	9235,8
ТП-5	2	3	223,0	222,0	222,0	15,0	57,0	14,0	19107,0

№ ТП	Сек (Щит)	Группа (ВЛ)	УАО, В	УВ0, В	УСО, В	IA, А	IB, А	IC, А	P, Вт
ТП-5	2	11	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-5	2	12	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-6	1	0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-6	1	11	234,0	233,0	233,0	80,0	60,0	70,0	49010,0
ТП-6	1	12	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-6	2	0	235,0	234,0	234,0	50,6	50,8	50,9	35688,8
ТП-6	2	11	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-6	2	12	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-7	1	1	237,0	236,0	236,0	12,0	12,0	10,0	8036,0
ТП-7	1	2	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-7	1	3	237,0	236,0	236,0	58,0	59,0	59,0	41594,0
ТП-7	1	6	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-7	2	1	235,0	235,0	234,0	36,0	36,0	36,0	25344,0
ТП-7	2	2	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-7	2	3	235,0	235,0	234,0	0,1	0,0	0,0	23,5
ТП-7	2	4	235,0	235,0	234,0	3,0	3,0	3,0	2112,0
ТП-7	2	6	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-7А	1	1	235,0	237,0	236,0	47,0	44,0	33,0	29261,0
ТП-7А	1	5	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-7А	1	6	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-7А	2	1	237,0	238,0	237,0	0,0	0,0	0,0	0,0
ТП-7А	2	5	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-7А	2	6	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-10	1	15	236,0	236,0	235,0	60,0	6,0	150,0	50826,0
ТП-10	1	16	236,0	236,0	235,0	16,0	22,0	0,0	8968,0
ТП-10	2	15	236,0	236,0	236,0	0,0	0,0	0,0	0,0
ТП-10	2	16	236,0	236,0	236,0	0,01	0,01	0,02	9,4
ТП-Альфа	1	0	237,0	237,0	236,0	0,0	0,0	0,0	0,0
ТП-Альфа	2	0	238,0	237,0	237,0	0,01	0,0	0,0	2,4
ТП-Альфа	1	16	237,0	237,0	236,0	0,0	0,0	0,0	0,0
ТП-Альфа	2	16	238,0	237,0	237,0	0,04	0,0	0,0	9,5
ТП-2224	1	0	245,0	244,0	244,0	0,59	0,61	0,67	456,9
ТП-2224	1		245,0	244,0	244,0	0,0	0,0	0,0	0,0
ТП-2224	1		245,0	244,0	244,0	0,0	0,0	0,0	0,0
ТП-2224	1		245,0	244,0	244,0	0,0	0,0	0,0	0,0
ТП-2224	1		245,0	244,0	244,0	0,0	0,0	0,0	0,0
ТП-2224	1		245,0	244,0	244,0	0,0	0,0	0,0	0,0
ТП-2224	1		245,0	244,0	244,0	0,0	0,0	0,0	0,0
ТП-2224	1		245,0	244,0	244,0	0,0	0,0	0,0	0,0
ТП-2224	2	0	241,0	239,0	240,0	0,68	0,97	0,61	542,1
ТП-2224	2		241,0	239,0	240,0	34,0	42,0	26,0	24472,0
ТП-2224	2		241,0	239,0	240,0	36,0	37,0	39,0	26879,0
ТП-2224	2		241,0	239,0	240,0	58,0	85,0	42,0	44373,0
ТП-2224	2		241,0	239,0	240,0	50,0	39,0	40,0	30971,0
ТП-2224	2		241,0	239,0	240,0	34,0	43,0	31,0	25911,0
ТП-2224	2		241,0	239,0	240,0	44,0	45,0	23,0	26879,0
ТП-2224	2		241,0	239,0	240,0	29,0	26,0	28,0	19923,0
ТП-2224	2		241,0	239,0	240,0	32,0	70,0	22,0	29722,0
ТП-37	1	24	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-37	2	23	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-37	2	24	238,0	238,0	237,0	0,0	0,1	0,0	23,8

№ ТП	Сек (Щит)	Группа (ВЛ)	УАО, В	УВО, В	УСО, В	IA, А	IB, А	IC, А	P, Вт
ТП-39	1	0	239,0	238,0	238,0	0,14	0,22	0,00	85,8
ТП-39	1	1	239,0	238,0	238,0	3,8	0,6	2,4	1622,2
ТП-39	1	2	239,0	238,0	238,0	0,0	0,0	0,0	0,0
ТП-39	1	5	239,0	238,0	238,0	11,0	24,0	14,0	11673,0
ТП-39	1	6	239,0	238,0	238,0	2,6	28,0	2,6	7904,2
ТП-39	1	7	239,0	238,0	238,0	2,0	8,0	12,0	5238,0
ТП-39	1	9	239,0	238,0	238,0	14,0	15,0	1,8	7344,4
ТП-39	1	23	239,0	238,0	238,0	180,0	22,0	14,0	51588,0
ТП-39	1	24	239,0	238,0	238,0	0,0	0,0	7,0	1666,0
ТП-39	2	0	238,0	238,0	237,0	0,104	0,086	0,101	69,2
ТП-39	2	1	238,0	238,0	237,0	5,0	9,0	3,0	4043,0
ТП-39	2	2	238,0	238,0	237,0	0,6	0,0	0,0	142,8
ТП-39	2	5	238,0	238,0	237,0	11,0	3,0	4,0	4280,0
ТП-39	2	6	238,0	238,0	237,0	12,0	5,0	13,0	7127,0
ТП-39	2	7	238,0	238,0	237,0	0,4	0,1	0,0	119,0
ТП-39	2	9	238,0	238,0	237,0	10,0	3,0	5,0	4279,0
ТП-39	2	24	238,0	238,0	237,0	20,0	27,0	50,0	23036,0
ТП-40	1	0	239,0	238,0	239,0	0,06	0,05	0,09	47,8
ТП-40	1	1	239,0	238,0	239,0	8,0	9,0	13,0	7161,0
ТП-40	1	3	239,0	238,0	239,0	0,0	1,0	0,0	238,0
ТП-40	1	5	239,0	238,0	239,0	12,0	4,0	5,0	5015,0
ТП-40	1	7	239,0	238,0	239,0	2,0	4,0	1,0	1669,0
ТП-40	1	9	239,0	238,0	239,0	1,6	2,0	2,0	1336,4
ТП-40	1	11	239,0	238,0	239,0	0,0	0,0	0,0	0,0
ТП-40	1	23	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-40	1	24	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-40	2	0	238,0	238,0	238,0	1,0	0,01	10,0	2620,4
ТП-40	2	1	238,0	238,0	238,0	4,0	5,7	25,0	8258,6
ТП-40	2	3	238,0	238,0	238,0	0,3	0,0	0,0	71,4
ТП-40	2	5	238,0	238,0	238,0	2,0	3,0	1,0	1428,0
ТП-40	2	7	238,0	238,0	238,0	0,3	0,1	1,5	452,2
ТП-40	2	9	238,0	238,0	238,0	0,0	0,0	0,0	0,0
ТП-40	2	11	238,0	238,0	238,0	0,0	0,0	0,0	0,0
ТП-40	2	23	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-40	2	24	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-41	1	0	237,0	236,0	236,0	9,1	9,7	9,9	6782,3
ТП-41	1	1	237,0	236,0	236,0	9,6	9,6	9,0	6664,8
ТП-41	1	6	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-41	2	0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-41	2	1	237,0	237,0	236,0	0,0	0,8	2,4	756,0
ТП-41	2	6	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-42	1	0	239,0	239,0	238,0	0,0	0,0	0,0	0,0
ТП-42	1	1	239,0	239,0	238,0	11,0	4,3	1,7	4061,3
ТП-42	1	15	239,0	239,0	238,0	0,6	0,6	8,0	2190,8
ТП-42	1	16	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-42	2	0	238,0	238,0	237,0	0,0	0,0	0,0	0,0
ТП-42	2	1	238,0	238,0	237,0	0,0	0,0	0,0	0,0
ТП-42	2	16	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-43	1	11	235,0	235,0	234,0	14,0	19,0	9,0	9861,0
ТП-43	1	12	238,0	237,0	237,0	0,2	11,0	2,0	3128,6
ТП-43	2	11	238,0	237,0	237,0	0,0	0,0	0,0	0,0

№ ТП	Сек (Щит)	Группа (ВЛ)	УАО, В	УВО, В	УСО, В	IA, А	IB, А	IC, А	P, Вт
ТП-43	2	12	236,0	235,0	235,0	0,2	23,0	0,9	5663,7
ТП-46	1	15	236,0	235,0	235,0	0,0	0,0	0,0	0,0
ТП-46	2	15	241,0	240,0	240,0	0,07	0,09	0,07	55,3
ТП-46	1	16	241,0	240,0	240,0	0,20	0,19	0,26	156,2
ТП-46	2	16	242,0	241,0	240,0	0,0	0,0	0,0	0,0
ТП-50	1	6	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-50	1	12	242,0	241,0	240,0	0,0	0,0	0,0	0,0
ТП-2229	1	0	242,0	241,0	241,0	0,24	0,26	0,13	152,1
ТП-2229	1	15	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-2229	1	16	238,0	238,0	237,0	0,0	0,0	0,0	0,0
ТП-2229	2	0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-2229	2	15	237,0	236,0	236,0	0,0	0,0	0,0	0,0
ТП-2229	2	16	0,0	0,0	0,0	0,0	0,0	0,0	0,0
СТП	1	0	235,0	235,0	234,0	14,0	19,0	9,0	9861,0
ТП-72	1	15	238,0	237,0	237,0	0,2	11,0	2,0	3128,6
ТП-72	1	16	238,0	237,0	237,0	0,0	0,0	0,0	0,0
ТП-72	2	15	236,0	235,0	235,0	0,2	23,0	0,9	5663,7
ТП-72	2	16	236,0	235,0	235,0	0,0	0,0	0,0	0,0
РТП-59	1	0	241,0	240,0	240,0	0,07	0,09	0,07	55,3
РТП-59	2	0	241,0	240,0	240,0	0,20	0,19	0,26	156,2
РТП-60	2	0	242,0	241,0	240,0	0,0	0,0	0,0	0,0
РТП-60	2	1	0,0	0,0	0,0	0,0	0,0	0,0	0,0
РТП-60	2	13	242,0	241,0	240,0	0,0	0,0	0,0	0,0
РТП-60	1	0	242,0	241,0	241,0	0,24	0,26	0,13	152,1
РТП-60	1	1	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-71	1	15	238,0	238,0	237,0	0,0	0,0	0,0	0,0
ТП-71	1	16	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-71	2	15	237,0	236,0	236,0	0,0	0,0	0,0	0,0
ТП-71	2	16	0,0	0,0	0,0	0,0	0,0	0,0	0,0
ТП-65	1	0	237,0	236,0	236,0	0,0	0,0	0,0	0,0
ТП-65	2	0	236,0	235,0	235,0	0,0	0,0	0,0	0,0
ТП-73	1	15	237,0	237,0	236,0	0,0	0,0	0,0	0,0
ТП-73	1	16	237,0	237,0	236,0	22,0	29,0	14,0	15391,0
ТП-73	2	15	236,0	235,0	235,0	34,0	20,0	31,0	20009,0
ТП-73	2	16	236,0	235,0	235,0	63,0	53,0	50,0	39073,0
ТП-4135	1	0	230,0	230,0	229,0	0,52	0,47	0,54	351,4
ТП-1418	1	0	237,0	236,0	236,0	0,0	0,0	0,0	0,0
ТП-1418	1	1	236,0	235,0	235,0	0,0	0,0	0,0	0,0
ТП-1418	1	2	237,0	237,0	236,0	0,0	0,0	0,0	0,0
ТП-1418	1	3	237,0	237,0	236,0	22,0	29,0	14,0	15391,0
ТП-1418	1	6	236,0	235,0	235,0	34,0	20,0	31,0	20009,0
ТП-1418	1	8	236,0	235,0	235,0	63,0	53,0	50,0	39073,0
ТП-1418	2	0	230,0	230,0	229,0	0,52	0,47	0,54	351,4
ТП-1418	2	1	234	232	232	120,0	80,0	180,0	88400,0
ТП-1418	2	2	234	232	232	1,0	3,0	1,0	1162,0
ТП-1418	2	4	234	232	232	1,0	1,0	3,0	1162,0
ТП-1418	2	5	234	232	232	0,0	0,0	0,0	0,0
ТП-1418	2	6	234	232	232	30,0	6,0	15,0	11892,0
ТП-1418	2	8	234	232	232	195,0	185,0	185,0	131470,0
ТП-4659	1	1	229,0	227,0	227,0	20	19	22	13887,0
ТП-4659	1	3	229,0	227,0	227,0	18,0	13,0	15,0	10478,0

№ ТП	Сек (Щит)	Группа (ВЛ)	УАО, В	УБО, В	УСО, В	IA, А	IB, А	IC, А	P, Вт
ТП-4659	1	5	229,0	227,0	227,0	10,0	12,0	14,0	8192,0
ТП-4659	1	6	229,0	227,0	227,0	17,0	20,0	18,0	12519,0
ТП-4659	1	7	229,0	227,0	227,0	17,0	18,0	20,0	12519,0
ТП-4659	1	8	229,0	227,0	227,0	19,0	20,0	11,0	11388,0
ТП-4659	1	9	229,0	227,0	227,0	24,0	26,0	27,0	17527,0
ТП-4659	1	10	229,0	227,0	227,0	21,0	22,0	24,0	15251,0
ТП-4659	1	12	229,0	227,0	227,0	25,0	26,0	28,0	17983,0
ТП-4659	1	13	229,0	227,0	227,0	17,0	15,0	18,0	11384,0
ТП-4659	1	15	229,0	227,0	227,0	5,0	4,0	6,0	3415,0
ТП-4659	2	1	228	227	227	14	15	16	10229,0
ТП-4659	2	3	228	227	227	32	35	30	22051,0
ТП-4659	2	5	228	227	227	14	13	16	9775,0
ТП-4659	2	6	228	227	227	16	18	20	12274,0
ТП-4659	2	7	228	227	227	17	19	20	12729,0
ТП-4659	2	8	228	227	227	13	14	14	9320,0
ТП-4659	2	9	228	227	227	19	12	10	9326,0
ТП-4659	2	10	228	227	227	23	30	24	17502,0
ТП-4659	2	12	228	227	227	21	22	24	15230,0
ТП-4659	2	13	228	227	227	25	26	28	17958,0
ТП-4660	1	1	224	222	222	11	12	13	8014,0
ТП-4660	1	2	224,0	222,0	222,0	12,0	14,0	15,0	9126,0
ТП-4660	1	3	224,0	222,0	222,0	12,0	16,0	13,0	9126,0
ТП-4660	1	4	224,0	222,0	222,0	14,0	17,0	15,0	10240,0
ТП-4660	1	5	224,0	222,0	222,0	15,0	17,0	16,0	10686,0
ТП-4660	1	6	224,0	222,0	222,0	18,0	20,0	21,0	13134,0
ТП-4660	1	7	224,0	222,0	222,0	24,0	25,0	26,0	16698,0
ТП-4660	1	8	224,0	222,0	222,0	27,0	30,0	31,0	19590,0
ТП-4660	1	9	224,0	222,0	222,0	10,0	13,0	12,0	7790,0
ТП-4660	2	1	226	225	229	20	22	21	14279,0
ТП-4660	2	2	226	225	229	17	18	20	12472,0
ТП-4660	2	3	226	225	229	19	20	17	12687,0
ТП-4660	2	4	226	225	229	12	11	10	7477,0
ТП-4660	2	5	226	225	229	21	22	24	15192,0
ТП-4660	2	6	226	225	229	25	26	28	17912,0
ТП-4660	2	7	226	225	229	20	29	34	18831,0
ТП-4660	2	8	226	225	229	14	13	16	9753,0
ТП-4660	2	9	226	225	229	16	18	20	12246,0
ТП-2762	1	0	232	231	232	825,0	864,0	832,0	584008,0
ТП-2762	2	0	234	232	232	1015,0	995,0	1024,0	705918,0
ТП-21	1	0	232	231	232	210	215	206	146177,0
ТП-21	1	1	232	231	232	18	20	17	12740,0
ТП-21	1	2	232	231	232	21	20	19	13900,0
ТП-21	1	3	232	231	232	12	11	14	8573,0
ТП-21	1	4	232	231	232	18	20	22	13900,0
ТП-21	1	5	232	231	232	60	57	53	39383,0
ТП-21	1	6	232	231	232	24	26	27	17838,0
ТП-21	1	7	232	231	232	25	26	28	18302,0
ТП-21	1	8	232	231	232	21	22	24	15522,0
ТП-21	1	12	232	231	232	19	16	18	12280,0
ТП-21	2	0	231	230	232	195	192	191	133517,0
ТП-21	2	1	231	230	232	9	10	12	7163,0



№ ТП	Сек (Щит)	Группа (ВЛ)	УАО, В	УВО, В	УСО, В	IA, А	IB, А	IC, А	P, Вт
ТП-21	2	2	231	230	232	7	9	8	5543,0
ТП-21	2	3	231	230	232	6	7	5	4156,0
ТП-21	2	4	231	230	232	15	16	14	10393,0
ТП-21	2	5	231	230	232	37	41	29	24705,0
ТП-21	2	6	231	230	232	21	22	24	15479,0
ТП-21	2	7	231	230	232	24	26	27	17788,0
ТП-21	2	8	231	230	232	25	26	28	18251,0
ТП-21	2	10	231	230	232	16	15	14	10394,0
ТП-22	1	0	234	232	232	320	332	315	224984,0
ТП-22	1	1	234	232	232	11	13	14	8838,0
ТП-22	1	2	234	232	232	15	14	17	10702,0
ТП-22	1	3	234	232	232	16	18	14	11168,0
ТП-22	1	4	234	232	232	28	30	27	19776,0
ТП-22	1	5	234	232	232	8	9	10	6280,0
ТП-22	1	6	234	232	232	26	32	30	20468,0
ТП-22	1	7	234	232	232	24	27	26	17912,0
ТП-22	1	8	234	232	232	7	10	9	6046,0
ТП-22	1	9	234	232	232	19	20	23	14422,0
ТП-22	1	10	234	232	232	22	25	20	15588,0
ТП-22	1	11	234	232	232	12	15	13	9304,0
ТП-22	1	12	234	232	232	21	23	20	14890,0
ТП-22	1	13	234	232	232	20	25	23	15816,0
ТП-22	1	14	234	232	232	14	17	15	10700,0
ТП-22	1	15	234	232	232	20	25	23	15816,0
ТП-22	1	16	234	232	232	12	15	13	9304,0
ТП-22	2	0	233	234	233	335	329	340	234261,0
ТП-22	2	1	233	234	233	8	9	12	6766,0
ТП-22	2	2	233	234	233	20	18	22	13998,0
ТП-22	2	3	233	234	233	12	13	15	9333,0
ТП-22	2	4	233	234	233	14	15	16	10500,0
ТП-22	2	5	233	234	233	26	28	30	19600,0
ТП-22	1	6	233	234	233	29	25	28	19131,0
ТП-22	1	7	233	234	233	20	22	18	14002,0
ТП-22	2	8	233	234	233	16	15	16	10966,0
ТП-22	2	9	233	234	233	20	18	21	13765,0
ТП-22	2	10	233	234	233	28	35	32	22170,0
ТП-22	2	11	233	234	233	10	15	14	9102,0
ТП-22	2	12	233	234	233	18	17	20	12832,0
ТП-22	2	13	233	234	233	17	12	10	9099,0
ТП-22	2	14	233	234	233	19	10	13	9796,0
ТП-22	2	15	233	234	233	14	17	15	10735,0
ТП-22	2	16	233	234	233	12	15	13	9335,0
ТП-23	1	0	231	232	232	120	126	136	88504,0
ТП-23	1	1	231	232	232	11	13	15	9037,0
ТП-23	1	2	231	232	232	6	6	5	3938,0
ТП-23	1	3	231	232	232	10	13	11	7878,0
ТП-23	1	4	231	232	232	11	14	15	9269,0
ТП-23	1	5	231	232	232	7	10	8	5793,0
ТП-23	1	7	231,0	232,0	232,0	11,0	10,0	12,0	7645,0
ТП-23	1	8	231,0	232,0	232,0	11,0	12,0	14,0	8573,0
ТП-23	1	9	231,0	232,0	232,0	13,0	15,0	14,0	9731,0

№ ТП	Сек (Щит)	Группа (ВЛ)	УАО, В	УВО, В	УСО, В	IA, А	IB, А	IC, А	P, Вт
ТП-23	1	10	231,0	232,0	232,0	6,0	8,0	10,0	5562,0
ТП-23	1	14	231,0	232,0	232,0	7,0	10,0	6,0	5329,0
ТП-23	2	0	230	231	231	150	162	168	110730,0
ТП-23	2	1	230	231	231	15	18	17	11535,0
ТП-23	2	2	230	231	231	13	15	14	9689,0
ТП-23	2	3	230	231	231	11	10	9	6919,0
ТП-23	2	4	230	231	231	3	4	4	2538,0
ТП-23	2	5	230	231	231	31	32	28	20990,0
ТП-23	2	6	230	231	231	9	10	11	6921,0
ТП-23	2	7	230	231	231	3	4	3	2307,0
ТП-23	2	8	230	231	231	13	12	11	8303,0
ТП-23	2	9	230	231	231	8	10	7	5767,0
ТП-23	2	10	230	231	231	26	30	28	19378,0
ТП-24	1	0	232	233	232	170	166	175	118718,0
ТП-24	1	1	232	233	232	9	10	12	7202,0
ТП-24	1	2	232	233	232	15	17	14	10689,0
ТП-24	1	3	232	233	232	18	10	12	9290,0
ТП-24	1	4	232	233	232	17	18	10	10458,0
ТП-24	1	5	232	233	232	15	15	16	10687,0
ТП-24	1	6	232	233	232	12	13	12	8597,0
ТП-24	1	7	232	233	232	13	14	15	9758,0
ТП-24	1	8	232	233	232	12	14	12	8830,0
ТП-24	1	9	232	233	232	36	38	35	25326,0
ТП-24	1	10	232	233	232	21	18	15	12546,0
ТП-24	1	14	232	233	232	7	9	10	6041,0
ТП-24	2	0	233	231	232	160	158	166	112290,0
ТП-24	2	1	233	231	232	18	10	17	10448,0
ТП-24	2	2	233	231	232	16	17	18	11831,0
ТП-24	2	3	233	231	232	14	15	15	10207,0
ТП-24	2	4	233	231	232	19	10	18	10913,0
ТП-24	2	5	233	231	232	29	32	30	21109,0
ТП-24	2	6	233	231	232	10	12	11	7654,0
ТП-24	2	7	233	231	232	10	12	14	8350,0
ТП-24	2	8	233	231	232	10	12	11	7654,0
ТП-24	2	9	233	231	232	22	25	24	16469,0
ТП-24	2	10	233	231	232	25	26	32	19255,0
ТП-25	1	0	232	233	232	262	257	270	183305,0
ТП-25	1	1	232	233	232	9	10	12	7202,0
ТП-25	1	2	232	233	232	25	24	21	16264,0
ТП-25	1	3	232	233	232	19	23	21	14639,0
ТП-25	1	4	232	233	232	24	27	25	17659,0
ТП-25	1	5	232	233	232	3	5	4	2789,0
ТП-25	1	6	232	233	232	3	3	4	2323,0
ТП-25	1	7	232	233	232	21	24	27	16728,0
ТП-25	1	8	232	233	232	18	21	20	13709,0
ТП-25	1	9	232	233	232	16	18	15	11386,0
ТП-25	1	10	232	233	232	18	22	21	14174,0
ТП-25	1	11	232	233	232	9	12	10	7204,0
ТП-25	1	12	232	233	232	12	14	10	8366,0
ТП-25	1	13	232	233	232	14	18	16	11154,0
ТП-25	1	14	232	233	232	24	25	22	16497,0

№ ТП	Сек (Щит)	Группа (ВЛ)	УАО, В	УВО, В	УСО, В	IA, А	IB, А	IC, А	P, Вт
ТП-25	1	15	232	233	232	8	7	6	4879,0
ТП-25	1	16	232	233	232	20	19	22	14171,0
ТП-25	1	17	232	233	232	9	10	12	7202,0
ТП-25	1	18	232	233	232	4	5	4	3021,0
ТП-25	1	23	232	233	232	7	9	5	4881,0
ТП-25	2	0	233	231	232	255	241	234	169374,0
ТП-25	2	1	233	231	232	20	19	22	14153,0
ТП-25	2	2	233	231	232	16	17	20	12295,0
ТП-25	2	3	233	231	232	12	15	11	8813,0
ТП-25	2	4	233	231	232	22	20	24	15314,0
ТП-25	2	5	233	231	232	14	15	16	10439,0
ТП-25	2	6	233	231	232	16	14	15	10442,0
ТП-25	2	7	233	231	232	11	12	13	8351,0
ТП-25	2	8	233	231	232	18	16	12	10674,0
ТП-25	2	9	233	231	232	17	10	19	10679,0
ТП-25	2	10	233	231	232	10	15	12	8579,0
ТП-25	2	11	233	231	232	10	12	14	8350,0
ТП-25	2	12	233	231	232	10	16	14	9274,0
ТП-25	2	13	233	231	232	12	15	13	9277,0
ТП-25	2	14	233	231	232	25	26	27	18095,0
ТП-25	2	15	233	231	232	18	20	21	13686,0
ТП-25	2	16	233	231	232	18	22	21	14148,0
ТП-25	2	17	233	231	232	9	12	10	7189,0
ТП-25	2	18	233	231	232	12	14	10	8350,0
ТП-25	2	24	233	231	232	14	18	16	11132,0
ТП-26	1	0	232	233	232	55	60	52	38804,0
ТП-26	1	1	232	233	232	25	27	23	17427,0
ТП-26	1	2	232	233	232	20	21	28	16029,0
ТП-26	1	3	232	233	232	24	17	24	15097,0
ТП-26	1	5	232	233	232	25	27	24	17659,0
ТП-26	2	0	232	233	232	10	16	14	9296,0
ТП-26	2	1	233	231	232	57	60	58	40597,0
ТП-26	2	2	233	231	232	25	22	29	17635,0
ТП-26	2	3	233	231	232	24	23	25	16705,0
ТП-26	2	4	233	231	232	20	18	17	12762,0
ТП-33	1	0	230	231	230	232	229	209	154329,0
ТП-33	1	1	230	231	230	14	18	20	11978,0
ТП-33	1	2	230	231	230	15	20	16	11750,0
ТП-33	1	3	230	231	230	14	20	15	11290,0
ТП-33	1	4	230	231	230	21	15	25	14045,0
ТП-33	1	5	230	231	230	11	17	18	10597,0
ТП-33	1	6	230	231	230	15	10	10	8060,0
ТП-33	1	7	230	231	230	15	14	15	10134,0
ТП-33	1	8	230	231	230	16	18	16	11518,0
ТП-33	1	9	230	231	230	13	17	13	9907,0
ТП-33	1	10	230	231	230	23	16	17	12896,0
ТП-33	1	11	230	231	230	18	15	17	11515,0
ТП-33	1	12	230	231	230	15	16	14	10366,0
ТП-33	1	13	230	231	230	17	18	15	11518,0
ТП-33	1	14	230	231	230	12	14	12	8754,0
ТП-33	1	15	230	231	230	14	26	17	13136,0

№ ТП	Сек (Щит)	Группа (ВЛ)	УАО, В	УВО, В	УСО, В	IA, А	IB, А	IC, А	P, Вт
ТП-33	1	16	230	231	230	17	18	15	11518,0
ТП-33	1	17	230	231	230	12	14	12	8754,0
ТП-33	1	20	230	231	230	13	14	13	9214,0
ТП-33	2	0	231	232	232	212	204	216	146412,0
ТП-33	2	1	231	232	232	28	30	22	18532,0
ТП-33	2	2	231	232	232	17	18	15	11583,0
ТП-33	2	3	231	232	232	14	20	22	12978,0
ТП-33	2	4	231	232	232	21	15	25	14131,0
ТП-33	2	5	231	232	232	15	16	14	10425,0
ТП-33	2	6	231	232	232	13	15	17	10427,0
ТП-33	2	7	231	232	232	15	14	15	10193,0
ТП-33	2	8	231	232	232	16	18	16	11584,0
ТП-33	2	9	231	232	232	20	25	21	15292,0
ТП-33	2	10	231	232	232	19	18	16	12277,0
ТП-33	2	11	231	232	232	15	16	14	10425,0
ТП-33	2	12	231	232	232	18	10	17	10422,0
ТП-33	2	13	231	232	232	14	17	16	10890,0
ТП-33	2	14	231	232	232	17	10	19	10655,0
ТП-33	2	15	231	232	232	16	22	16	12512,0
ТП-33	2	16	231	232	232	24	15	26	15056,0
ТП-33	2	17	231	232	232	15	16	17	11121,0
ТП-35	1	0	232	233	232	227	232	221	157992,0
ТП-35	1	1	232	233	232	25	27	24	17659,0
ТП-35	1	2	232	233	232	16	17	18	11849,0
ТП-35	1	3	232	233	232	8	11	10	6739,0
ТП-35	1	4	232	233	232	19	20	18	13244,0
ТП-35	1	5	232	233	232	29	32	30	21144,0
ТП-35	1	6	232	233	232	20	22	21	14638,0
ТП-35	1	7	232	233	232	20	19	24	14635,0
ТП-35	1	8	232	233	232	14	11	16	9523,0
ТП-35	1	9	232	233	232	18	19	17	12547,0
ТП-35	1	10	232	233	232	21	22	21	14870,0
ТП-35	1	11	232	233	232	29	32	30	21144,0
ТП-35	1	12	232	233	232	19	20	18	13244,0
ТП-35	1	13	232	233	232	10	12	14	8364,0
ТП-35	1	14	232	233	232	15	16	19	11616,0
ТП-35	1	15	232	233	232	10	12	9	7204,0
ТП-35	1	16	232	233	232	11	13	10	7901,0
ТП-35	2	0	233	232	232	215	223	209	150319,0
ТП-35	2	1	233	232	232	29	26	25	18589,0
ТП-35	2	2	233	232	232	18	20	22	13938,0
ТП-35	2	3	233	232	232	8	9	6	5344,0
ТП-35	2	4	233	232	232	17	18	20	12777,0
ТП-35	2	5	233	232	232	12	13	12	8596,0
ТП-35	2	6	233	232	232	13	14	15	9757,0
ТП-35	2	7	233	232	232	22	24	22	15798,0
ТП-35	2	8	233	232	232	13	15	14	9757,0
ТП-35	2	10	233	232	232	18	20	22	13938,0
ТП-35	2	11	233	232	232	15	15	16	10687,0
ТП-35	2	12	233	232	232	22	23	22	15566,0
ТП-35	2	13	233	232	232	23	24	25	16727,0

№ ТП	Сек (Щит)	Группа (ВЛ)	УАО, В	УВ0, В	УСО, В	IA, А	IB, А	IC, А	P, Вт
ТП-35	2	14	233	232	232	22	24	22	15798,0
ТП-35	2	15	233	232	232	10	12	9	7202,0
ТП-35	2	16	233	232	232	8	9	6	5344,0
РТП-29	1	0	232	231	232	270	279	265	188569,0
РТП-29	1	1	232	231	232	56	53	54	37763,0
РТП-29	1	2	232	231	232	19	17	18	12511,0
РТП-29	1	3	232	231	232	8	9	6	5327,0
РТП-29	1	4	232	231	232	24	26	23	16910,0
РТП-29	1	4	232	231	232	13	14	12	9034,0
РТП-29	1	5	232	231	232	24	22	25	16450,0
РТП-29	1	6	232	231	232	13	15	16	10193,0
РТП-29	1	7	232	231	232	15	12	13	9268,0
РТП-29	1	8	232	231	232	17	14	16	10890,0
РТП-29	1	9	232	231	232	25	22	19	15290,0
РТП-29	1	10	232	231	232	17	14	15	10658,0
РТП-29	1	11	232	231	232	26	23	24	16913,0
РТП-29	1	12	232	231	232	1	1	1	695,0
РТП-29	1	13	232	231	232	14	13	12	9035,0
РТП-29	1	14	232	231	232	5	4	3	2780,0
РТП-29	1	16	232	231	232	8	9	6	5327,0
РТП-29	2	0	231	230	232	266	257	249	178324,0
РТП-29	2	1	231	230	232	3	2	3	1849,0
РТП-29	2	2	231	230	232	2	2	1	1154,0
РТП-29	2	3	231	230	232	8	8	7	5312,0
РТП-29	2	4	231	230	232	26	24	25	17326,0
РТП-29	2	5	231	230	232	22	20	23	15018,0
РТП-29	2	6	231	230	232	27	25	29	18715,0
РТП-29	2	7	231	230	232	11	13	10	7851,0
РТП-29	2	8	231	230	232	26	28	25	18246,0
РТП-29	2	9	231	230	232	18	19	17	12472,0
РТП-29	2	10	231	230	232	22	20	24	15250,0
РТП-29	2	11	231	230	232	21	23	19	14549,0
РТП-29	2	12	231	230	232	40	36	39	26568,0
РТП-29	2	13	231	230	232	11	10	12	7625,0
РТП-29	2	14	231	230	232	10	8	9	6238,0
РТП-29	2	15	231	230	232	10	12	9	7158,0
РТП-29	2	16	231	230	232	11	13	10	7851,0
ТП "Котельная"	1	0	240	237	237	55	46	43	34293,0
ТП "Котельная"	1	1	240	237	237	18	20	17	13089,0
ТП "Котельная"	1	2	240	237	237	24	26	27	18321,0
ТП "Котельная"	1	3	240	237	237	42	37	29	25722,0
ТП "Котельная"	2	0	239	237	237	52	56	45	36365,0
ТП-32	1	0	230	231	230	286	302	291	202472,0
ТП-32	1	1	230	231	230	20	21	16	13131,0
ТП-32	1	2	230	231	230	23	26	20	15896,0
ТП-32	1	3	230	231	230	21	32	30	19122,0
ТП-32	1	4	230	231	230	29	30	29	20270,0
ТП-32	1	5	230	231	230	20	19	18	13129,0
ТП-32	1	6	230	231	230	27	31	30	20271,0
ТП-32	1	8	230	231	230	40	42	39	27872,0
ТП-32	1	9	230	231	230	23	22	25	16122,0

№ ТП	Сек (Щит)	Группа (ВЛ)	УАО, В	УВО, В	УСО, В	IA, А	IB, А	IC, А	P, Вт
ТП-32	1	10	230	231	230	32	30	33	21880,0
ТП-32	1	12	230	231	230	20	22	23	14972,0
ТП-32	1	16	230	231	230	0	0	0	0,0
ТП-32	2	0	232	230	231	312	305	294	210448,0
ТП-32	2	1	232	230	231	25	23	21	15941,0
ТП-32	2	2	232	230	231	20	22	21	14551,0
ТП-32	2	3	232	230	231	25	27	24	17554,0
ТП-32	2	4	232	230	231	20	21	19	13859,0
ТП-32	2	5	232	230	231	28	25	26	18252,0
ТП-32	2	6	232	230	231	32	34	31	22405,0
ТП-32	2	8	232	230	231	40	38	42	27722,0
ТП-32	2	9	232	230	231	32	29	25	19869,0
ТП-32	2	10	232	230	231	45	40	37	28187,0
ТП-32	2	12	232	230	231	28	26	29	19175,0
ТП-32	2	13	232	230	231	29	30	32	21020,0
ТП-17	1	7	231	230	229	35	37	39	25526,0
ТП-17	1	8	231	230	229	40	33	42	26448,0
ТП-17	1	9	231	230	229	27	29	25	18632,0
ТП-17	1	10	231	230	229	33	37	35	24148,0
ТП-17	2	7	230	232	231	41	38	35	26331,0
ТП-17	2	8	230	232	231	43	35	40	27250,0
ТП-17	2	9	230	232	231	29	32	27	20331,0
ТП-17	2	10	230	232	231	40	42	46	29570,0
ТП-18	1	0	237	239	238	86	83	94	62591,0
ТП-18	1	11	237	239	238	54	59	67	42845,0
ТП-18	1	12	237	239	238	32	24	27	19746,0
ТП-18	2	0	238	237	236	68	59	71	46923,0
ТП-18	2	11	238	237	236	42	38	40	28442,0
ТП-18	2	12	238	237	236	26	21	31	18481,0
ТП-19	1	0	236	238	237	67	59	58	43600,0
ТП-19	1	1	236	238	237	8	10	7	5927,0
ТП-19	1	2	236	238	237	13	15	21	11615,0
ТП-19	1	3	236	238	237	18	12	10	9474,0
ТП-19	1	4	236	238	237	10	8	5	5449,0
ТП-19	1	5	236	238	237	7	4	6	4026,0
ТП-19	1	6	236	238	237	13	12	15	9479,0
ТП-19	1	7	236	238	237	2	4	5	2609,0
ТП-19	1	16	236	238	237	0	0	0	0,0
ТП-19	2	0	237	236	238	90	85	91	63048,0
ТП-19	2	1	237	236	238	10	7	6	5450,0
ТП-19	2	2	237	236	238	15	13	17	10669,0
ТП-19	2	3	237	236	238	13	16	22	12093,0
ТП-19	2	4	237	236	238	8	10	7	5922,0
ТП-19	2	5	237	236	238	9	15	12	8529,0
ТП-19	2	6	237	236	238	14	15	12	9714,0
ТП-19	2	7	237	236	238	3	6	8	4031,0
ТП-19	2	16	237	236	238	10	12	13	8296,0
ТП-45	2	23	227,0	227,0	226,0	3,0	108,0	114,0	50961,0
ТП-49	1	0	238,0	238,0	237,0	0,07	0,07	0,08	52,3
ТП-49	1	12	238,0	238,0	237,0	2,0	1,0	6,0	2136,0
ТП-49	2	0	0,0	0,0	0,0	0,0	0,0	0,0	0,0

№ ТП	Сек (Щит)	Группа (ВЛ)	UАО, В	UВ0, В	UС0, В	IA, А	IB, А	IC, А	P, Вт
ТП-1611	1	1	236,0	236,0	234,0	13,0	11,0	52,0	17832,0
ТП-1611	1	2	236,0	236,0	234,0	0,1	1,0	0,2	306,4
ТП-1611	1	3	236,0	236,0	234,0	0,3	1,2	7,0	1992,0
ТП-1611	1	4	236,0	236,0	234,0	8,0	9,0	9,0	6118,0
ТП-1612	1	1	235,0	236,0	236,0	30,0	16,0	10,0	13186,0
ТП-1612	1	2	235,0	236,0	236,0	4,0	19,0	18,0	9672,0
ТП-1612	1	3	235,0	236,0	236,0	5,0	2,0	4,0	2591,0
ТП-1613	1	1	240,0	240,0	240,0	6,0	8,0	3,0	4080,0
ТП-1613	1	2	240,0	240,0	240,0	16,0	18,0	17,0	12240,0
ТП-1613	1	3	240,0	240,0	240,0	20,0	37,0	36,0	22320,0
ТП-1613	1	4	240,0	240,0	240,0	2,0	1,2	0,3	840,0